

**SPECIAL COMMISSION MEETING AGENDA
TUESDAY, JULY 16, 2013
6:00 P.M.**

- A. CALL TO ORDER** – Mayor David George
- B. NEW BUSINESS**
 - 1. Resolution No. R-13-55 – A Resolution to authorize a purchase order to Locke Equipment Sales Company for repairs to boiler No. 5 in the Electric Utility.
- C. ADJOURN**

Budget work session to follow special meeting.

 <p style="text-align: center;">CITY OF COFFEYVILLE BOARD OF COMMISSIONERS AGENDA ITEM</p>	
MEETING DATE	July 16, 2013
RESOLUTION OR ORDINANCE NUMBER	R-13-55
AGENDA TITLE	Boiler No. 5 Repair
REQUESTING DEPARTMENT	Electric Generation
PRESENTER	Mike Shook
FISCAL INFORMATION	Cost as recommended: \$310,320.00
	Budget Line Item: 810-5-030-862
	Balance Available
	New Appropriation Required: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
PURPOSE	Emergent Repair of Boiler No. 5
BACKGROUND	<p>On June 24th, 2013, Boiler No. 5 suffered an internal furnace explosion causing major damage to 128 Boiler "D" Tubes.</p> <p>Staff has solicited sealed bids from three boiler repair contractors as recommended by Chubb Group of Insurance Companies and the State of Kansas Chief Boiler Inspector. Bids for repairs consisted of both hard quotes for the "D Tube" section replacement and time & material quotes for any additional emergent repairs that may be deemed necessary upon dismantling of damaged areas, as requested.</p>
SPECIAL NOTES	

ANALYSIS	<p>Bids were received from:</p> <ul style="list-style-type: none"> • Locke Equipment \$310,320.00 • North Point Boiler \$390,850.00 • Piping & Equipment \$562,982.01 <p>Staff has reviewed bids based on costs, estimated time for repairs and past experience with contractors.</p>
PUBLIC INFORMATION PROCESS	
BOARD OR COMMISSION RECOMMENDATION	
STAFF RECOMMENDATION	<p>Staff recommends issuance of purchase order to Locke Equipment Sales Company Inc. for the emergent repairs to Boiler No. 5, for "D" Tube section replacement in the amount not to exceed \$310,320.00. Additional emergent repairs made to Boiler 5 will be completed on a Time & Materials basis and invoiced separately.</p>
REFERENCE DOCUMENTS ATTACHED	Bids Received

RESOLUTION NO. R-13-55

A RESOLUTION TO AUTHORIZE THE ISSUANCE OF A PURCHASE ORDER TO LOCKE EQUIPMENT SALES COMPANY FOR THE EMERGENT REPAIRS TO BOILER NO. 5 "D" TUBE SECTION.

BE IT RESOLVED by the Board of Commissioners of the City of Coffeyville, Kansas that the Finance Director be and is hereby authorized and directed to issue a purchase order in the amount not to exceed \$310,320.00 to Locke Equipment Sales Company for the emergent repairs to Boiler No. 5 "D" Tube section, including additional repairs deemed necessary completed on a Time & Materials basis and invoiced separately for the City of Coffeyville Electric Utility.

ADOPTED THIS 16th DAY OF July, 2013.

David George, Mayor

ATTEST:

Cindy Price, City Clerk

APPROVED AS TO FORM AND LEGALITY:

Paul Kritz, City Attorney




Locke Equipment
Sales Co., Inc.
1917 E. Spruce
Olathe, KS 66062
913 782 8500

Date: 7-10-13

To: Mike Shook

Re: Nebraska Boiler 5 Repairs

From: Ron Cornish
Tim Locke



Associated Mechanical, Inc.
PO Box 2448
Shawnee Mission, KS 66201
913-815-1108


**Mike Shook / City Clerk
Coffeyville Kansas Utility
Coffeyville Kansas**

Re: Nebraska Boiler 5 Repair


Associated Mechanical Inc. is pleased to offer our services to repair the Nebraska boiler located in the central power plant for the City of Coffeyville.

The following items are covered in our proposal.


- All labor, materials and equipment needed to perform the repairs as shown and listed
- The casing on the D-tube side wall that has been damaged as shown in picture will be completely replaced with new casing materials.



- There are 126 D tubes that have been damaged as the picture shows they are bowed out about 7 ". Our proposal includes the supply, removal and replacement of these tubes.




- At the time of inspection the division wall tubes do not look to be damaged,
- Generating bank side of the boiler has damage to the casing and seals, the repair would require the removal of the casing and its replacement, this work will be performed T&M.



- At time of inspection it is not known if there is damage to the convection wall tubes in this area because of the lack of inspection doors. Once boiler is opened up the area can be properly looked at and repairs can be made. Work to be done T&M
- The area of the boilers superheater inlet and outlet indicate that damage has been done in this area of the boiler because of the rotation of the superheater piping as shown in the picture proper pricing cannot be given for the work in this area untell casing is removed. Work to be done T&M.





- The boilers roof was damaged and will be in need of repair also. It is our intent to reuse the roof steel once removed from the boiler and reinstalled, this work is included in our base bid.



- Both the front and rear wall seem to not have any major damage but there will need to be some welding done to joints that broke repairs to be done T&M.
- The boiler outlet expansion joint appears to be ok.

- The boilers front and rear refractory walls show signs of normal usage but no real damage.
- The boilers outlet to the economizer has been damaged and is pushed out and touching the support steel this duct will be repaired but not replaced. As you can see in the two pictures the deformed ducting. Repairs to be done T&M.



The Following is Included in our base bid.

- All Labor, equipment and materials to remove and replace 126 D Tubes.
- The replacement of the insulation on the roof and D Tube side wall and floor is included in proposal.
- New upper and lower refractory seals are included in pricing.
- New D Tube side wall casing and stiffeners are included.
- Replacement of D Tube casing ties in steel to roof casing.
- Lifting and lowering of roof catwalk.
- New scallop bars upper and lower that have to be removed and reinstalled to get D Tubes in and out of boiler.
- New D tube front and rear walls seals.

The following is the cost break down for D tube replacement. Some of our assumptions may not be included in competitive proposals:

1. D tube materials	\$58,696
2. D tube labor including rolling, membrane welding and R stamp, new casing materials, A.I.	\$188,976
3. Optional end wall seal replacement and Scallop bar removal and replacement.....	\$22,782
4. Refractory subcontractor for drum seals and insulation.....	\$18,522
5. Scaffold rental.....	\$ 3,000

Total if work is done working 40 hour weeks if all options are taken.

\$ 291,976.00

Total if work is done working two shifts of 6-10s

\$ 310,320.00

The Following will be done on T&M

- Convection sidewall casing replacement or repairs
- Outlet Duct repairs.
- Superheater unit / hanger repairs.
- Convection side wall tube repairs if needed.
- Welding of cracks in casing caused by explosion.
- Insulation needed on convection side wall.
- Refractory repairs if needed front and rear walls
- Refractory repairs to convection wall seals if needed.

Clarifications:

Please see attached sheet for T&M rates.

All work is bid working 40 hour work week's one shift.

Associated Mechanical Inc does not have any painting of the repaired boiler in the cost listed above.

The bake out of new refractory and its cost are not included.

Tube delivery is 3 weeks from order.

Associated Mechanical Inc. assumes the following items.

All hazardous material identification, removal, abatement, and disposal will be done by others. The cost of delays caused by hazardous materials or suspect hazardous materials is not included.

All scrap and waste materials will be disposed of by AMI into owner supplied dumpsters.

All necessary electricity, water and compressed air will be provided by plant services. This includes an electrician to connect equipment if necessary.

Break areas

Lock out and tag out will be supplied by the owner.

Sales tax will be added to the invoice amount if an exemption certificate is not provided.

Associated Mechanical Inc. would like to thank you for this opportunity to provide you with our services. We would appreciate an opportunity to discuss our offer. If you have any further questions or are in need of additional information please feel free to contact us at the above locations.

Sincerely,

Ron Cornish & Tim Locke

Associated Mechanical Inc
Locke Equipment
913 815-1116



Locke Equipment
Sales Co., Inc.
1917 E. Spruce
Olathe, KS 66062
913 782 8500


Date: 6-1-13

To: City of Coffeyville

Re: Labor Rates

From: Ron Cornish

ron@amikc.com



A.M.I.

Associated Mechanical, Inc.
PO Box 2448
Shawnee Mission, KS 66201
913-815-1108

Certified NWBOC CSW 6952

Associated Mechanical Inc labor rates for Boilermakers are as follows.

ST = Straight Time

OT = Overtime

DT= Double Time (Holidays and Sundays)

Boilermaker Journeyman / Welder

ST - \$ 82.77

OT - \$ 121.08

DT - \$ 159.38

Boilermaker Forman

ST - \$ 86.32

OT - \$ 126.40

DT - \$ 166.47

Boilermaker General Forman

ST - \$ 88.45

OT- \$ 129.59

DT- \$ 170.73

Materials are marked up 10%

Equipment & Tooling rentals mark up 10%

Travel is billed at straight time.

Consumables 10%

Trucks are billed at \$ 80.00 per day.

Per Diem rates are as follows.

Composite Crew or full time Associated Mechanical Personal gets \$ 110.00 per day

We will provide you a list of our full time crew.

Boilermakers dispatched from the Union Hall get \$ 80.00 per day


Kansas Statewide Certification Program

This is to certify **Associated Mechanical, Inc.** qualifies as a
Woman Business Enterprise (WBE)
and has met the eligibility criteria established by the State of Kansas,
Office of Minority and Women Business Development

NAICS Code/Work Type(s): **238220-Plumbing, Heating and Air-Conditioning Contractors**

5/15/12
Effective Date

3/15/15
Renewal Date



Rhonda Harris, Director
Office of Minority & Women Business
Development





hereby grants

National Women's Business Enterprise Certification to Associated Mechanical

who has successfully met WBENC's standards as a Women's Business Enterprise (WBE).
This certification affirms the business is woman-owned, operated and controlled; and is valid through the date herein.

WBENC National WBE Certification was processed and validated by Women's Business Development Center – Chicago, a WBENC Regional Partner Organization.

Expiration Date: 05/31/2014
WBENC National Certificate Number: 2005115668

Authorized by Hedy M. Ratner, Co-President, S. Carol Dougal, Co-President
Women's Business Development Center – Chicago



NAICS Codes: 238220, 238990, 238290, 811310

UNSPSC Codes: 40181800, 40181900, 40101834, 40102001, 73181902, 73181901, 73181903, 72151502, 40102004





Boiler and Combustion
24 Hour Service
Code Stamp Certification

July 2, 2013

Coffeyville Electric Utility
102 w 7th street
PO Box 1629
Coffeyville, KS 67337

Attention: Michael Shook

Re: Nebraska Boiler "D" tubes

Dear Mr. Shook:

North Point Boiler and Combustions is pleased to quote the following listed below for the lump sum amount of **\$390,850.00**

- Supply labor and equipment on a 12hour overtime, round the clock basis to remove one hundred twenty eight (128) existing "D" tubes in one(1) Nebraska boiler located at Coffeyville Electric Utility.
- Remove and dispose of the existing outer and inner 12' x 42' "D" side casing, in and Owner supplied dumpster. Insulation included.
- Remove and save the existing 8' x 42' "D" roof outer and inner casing.
- Remove the existing steam drum internals to gain access to the "D" tube, tube ends.
- Remove and ship pattern tube to the tube supplier.
- Remove and save the existing 12" x 12" fire box refractory floor tiles.
- Remove and dispose of the upper and lower "D" tube fire box roof and floor refractory seals and dispose of in an Owner supplied dumpster.
- Remove the existing one hundred twenty eight (128) "D" tubes and drum stubs. Place scrap tubes in the Owner's outside power plant area.
- Install and seal torque roll one hundred twenty eight (128) new ASTM code "D" tubes.
- "R" stamp seal weld new tube fins per the original design.
- Hydrostatically pressure test at operating pressure to insure no leaks are present.
- Reinstall the existing 12" x 12" fire box refractory floor tiles.
- Supply and install Plicbrico refractory to the upper and lower "D" tube fire box seals. This area to install is approximately 9" x 18" x 4" tapered.
- Supply and install new "D" side inner casing, reinstall and seal weld the existing roof inner casing.
- Supply and install new roof and sidewall insulation.
- Supply and install new "D" side outer casing complete with twelve (12) new 2" x 2" x 1/4" x 12' angle iron supports.
- Reinstall and seal weld the existing out roof casing.
- Reinstall the existing steam drum internals and close the drum doorways.
- This scope of work does not include any asbestos removal or new outer casing painting.
- Please allow 3-4 weeks new "D" tube delivery upon pattern arrival at the suppliers location.

Page 2

July 2, 2013

Re: Nebraska Boiler "D" tubes

Thank you for allowing North Point Boiler & Combustion CO. to provide this quote. We are looking forward to complete this or any other projects you may have to come. If we can be of any other service, please feel free to contact the undersigned.

Sincerely,

NORTH POINT BOILER & COMBUSTION

PRICES GOOD FOR 30 DAYS



Thomas G. Scherman
General Manager

Any additional repairs beyond this scope, shall be completed at a Time & Material basis upon the Owner's approval.

Owner's Acceptance

Purchase Order Number

September 1, 2012 Through September 1, 2013
North Point Boiler and Combustion
1600 N Topping, Kansas City, MO 64120

Labor Rates and Charges

	<u>Straight</u> <u>Time</u>	<u>Overtime</u> <u>Time & ½</u>	<u>Overtime</u> <u>Double</u>
Boilermaker Journeyman	\$89.00	\$133.00	\$178.00
Boilermaker Technician	\$89.00	\$133.00	\$178.00
Boilermaker Foreman	\$92.00	\$138.00	\$184.00
Boilermaker General Foreman	\$94.00	\$141.00	\$188.00
Project Management	\$86.00		
Project Coordinator	\$52.00		

Union Contract expires 9/1/2013
Rates based on a 4 man Crew

ASME Fees:	\$250.00
Hartford AI:	Invoice cost plus 10%
Equipment Maintenance:	4% of Labor
Service Truck: Fuel Surcharge	\$140.00 a day
Materials and Consumables:	Cost plus 10%
Subcontractors:	Cost plus 10%
Per Diem over 8hrs work day:	\$85.00 daily per employee

PIPING & EQUIPMENT
CO., INC.

P.O. BOX 1065 WICHITA, KANSAS 67201

RECEIVED
JUL 12 2013
CITY CLERK

July 11, 2013

City of Coffeyville
102 West 7th
Coffeyville, KS 67337

Attn: City Clerk and Mike Shook


Re: Boiler 5 Repair

Here are the tube prices we promised, sorry it took so long. Please see that this delivery is less than four weeks, don't quite know how to take that since he verbally told me two weeks. We appreciate your patience on the pricing. There is a copy of the quote with this letter.

Our Price is:	Material (Tubes)	\$43,470.00
	7% Mark-Up	\$3,042.00
	Freight	<u>\$1,000.00</u>
	Total	\$47,512.00

Once again, sorry about the hold up on the pricing, please call if you have any questions.

Very Truly Yours
Piping & Equipment Co., Inc.


Kirk Epperson
General Superintendent



St. Louis, MO

Overland Park, KS

West Des Moines, IA

Omaha, NE

Divison of Holman Boiler Works – Dallas, TX

QUOTATION

TO: Kirk Epperson
Piping Equipment

DATE: July 10, 2013

RE: City of Coffeyville Tubes

We are pleased to offer the following tubes for the City of Coffeyville.

Qty (126) D-Tubes Serial # D-3645 Yr Built 1997 National Board # 3409	\$43,470 + Frt
---	-----------------------

Price does not include Freight from Lincoln Nebraska. Lead time is less then (4) wks.

PROPOSAL FURNISHED BY:
TRABUE INDUSTRIAL SYSTEMS

Tim Diedrick,
Sales Engineer

PIPING & EQUIPMENT

CO., INC.

P.O. BOX 1065 WICHITA, KANSAS 67201

July 9, 2013

City of Coffeyville
102 West 7th
Coffeyville, KS 67337

Attn: City Clerk and Mike Shook

Re: Boiler 5 Repair

We are pleased to quote the above referenced project. This price is based on a site visit we made this morning. We see the scope of the hard dollar portion of this project as:

1. Remove catwalk and top and side skin
2. Remove floor tile
3. Remove what refractory is in the way
4. Remove generator from steam drum
5. Install and leave the trolley beam in place
6. Remove existing D Tubes and prep for new ones
7. Install and roll new D Tubes
8. Blanket insulation between tubes and skin
9. Reinstall skin and repair
10. Hydro
11. Reinstall steam drum internals
12. Reinstall floor brick
13. Reinstall catwalk

We exclude from this price:

1. Any Sales or Services Taxes
2. Any Electrical
3. Any Refractory Work
4. Any Civil
5. Any Insulation other than blankets for roof and side wall
6. Any Forklift or Cranes
7. Any other work than remove and replace D Tubes
8. Any Material, no tube pricing in this quote

This price is based on 2 each 10 Hr Shifts, 7 Days a week for approximately three weeks. We have figured 4" of Kaowool for the roof, sidewall, and floor.

Our Price to do this project is: **\$515,470.010 (This quote is labor, equipment and insulation only)**

I will forward the tube pricing upon receipt. We appreciate your patience in this matter.

Very Truly Yours
Piping & Equipment Co., Inc.



Kirk Epperson
General Superintendent

Encl: Insurance Certificate

Installation Floater

Coverage	Installation of commercial piping and associated machinery including but not limited to refinery heat exchangers, valves, pumps and related rigging.
Limits	<ul style="list-style-type: none">\$ 1,000,000 Any One Installation Project\$ 1,000,000 Catastrophe Limit\$ 500,000 Transit\$ 500,000 Temporary Storage\$ 500,000 Flood Per Building or Structure\$ 500,000 Zones B, C or X and Annual Aggregate\$ 100,000 Testing
Causes of Loss	Risks of Direct Physical Loss or Damage unless the Loss is subject to an Exclusion or Limitation.
Coinsurance	Nil
Deductible	<ul style="list-style-type: none">\$ 2,500 Per Occurrence, except\$ 10,000 Per Occurrence - Wind/Hall\$ 50,000 Per Occurrence - Flood - Zone B\$ 25,000 Per Occurrence - Flood - Zone C or X
Valuation	Replacement Cost
Annual Rate	\$8,700 Deposit & Minimum Earned Annual Reporting @ \$.036/100 Based on \$24,500,000 Estimated Receipts



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
07/25/2012

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an **ADDITIONAL INSURED**, the policy(ies) must be endorsed. If **SUBROGATION IS WAIVED**, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER CA #0H64724 IMA, Inc. (Wichita Division) PO Box 2992 Wichita, KS 67201-2992	1-316-267-9221	CONTACT NAME: PHONE (A/C, No, Ext): 316 267-9221 E-MAIL ADDRESS: FAX (A/C, No): 316 266-6254
INSURED Piping & Equipment Co., Inc. PO Box 1065 Wichita, KS 67201-1065		INSURER(S) AFFORDING COVERAGE
		INSURER A: CHARTER OAK FIRE INS CO 25615
		INSURER B: NATIONAL UNION FIRE INS CO OF PITTS 19445
		INSURER C: TRAVELERS IND CO OF AMER 25666
		INSURER D:
		INSURER E:
		INSURER F:

COVERAGES CERTIFICATE NUMBER: 28418567 REVISION NUMBER:

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL SUBR INSR / WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	GENERAL LIABILITY <input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY <input type="checkbox"/> CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: <input type="checkbox"/> POLICY <input checked="" type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC		DTC00047C790COF12	08/01/12	08/01/13	EACH OCCURRENCE \$ 1,000,000 DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 300,000 MED EXP (Any one person) \$ 10,000 PERSONAL & ADV INJURY \$ 1,000,000 GENERAL AGGREGATE \$ 2,000,000 PRODUCTS - COMP/OP AGG \$ 2,000,000 \$
	AUTOMOBILE LIABILITY <input checked="" type="checkbox"/> ANY AUTO <input type="checkbox"/> ALL OWNED AUTOS <input type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> HIRED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS		DT8100047C790COF12	08/01/12	08/01/13	COMBINED SINGLE LIMIT (Ea accident) \$ 1,000,000 BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$ \$
B	UMBRELLA LIAB <input checked="" type="checkbox"/> OCCUR EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE DED <input checked="" type="checkbox"/> RETENTION \$ 0		BE23102179	08/01/12	08/01/13	EACH OCCURRENCE \$ 20,000,000 AGGREGATE \$ 20,000,000 \$
C	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below	Y/N N N/A	DTRUB0047C79012	08/01/12	08/01/13	<input checked="" type="checkbox"/> WC STATUTORY LIMITS <input type="checkbox"/> OTH-ER E.L. EACH ACCIDENT \$ 1,000,000 E.L. DISEASE - EA EMPLOYEE \$ 1,000,000 E.L. DISEASE - POLICY LIMIT \$ 1,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, if more space is required)
Re: Access Agreement. BKEP Operating L.L.C. and its affiliates are included as Additional Insured on the General Liability Policy if required by written contract or agreement, subject to the policy terms and conditions. Workers Compensation includes Alternate Employer Endorsement for Certificate Holder, subject to the policy terms and conditions

CERTIFICATE HOLDER**CANCELLATION**

Blank space for Certificate Holder information.

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.

AUTHORIZED REPRESENTATIVE
Deb. M. R.