

**RATE SCHEDULE GS-KCC-04
GENERAL SERVICE SCHEDULE
UNDER KCC JURISDICTION—CODE 09**

Availability:

To all customers in the service area located more than three (3) miles outside city limits under KCC jurisdiction of the department through a single meter for nonresidential use.

Character of Service:

At such phase and voltage as the department may have available for the customer's location and requirements for secondary service. Multiple meters shall be individually metered.

Monthly Rates:

Subject to application of the Production Cost Adjustment - PCA-KCC-04.

Demand charge:

First 15 KW, Per KW	No Charge
Above 15 KW, Per KW	\$1.73

Energy Charge:

First 500 KWH, Per KWH	0.08511
Next 2,500 KWH, Per KWH	0.06382
Next 47,000 KWH, Per KWH	0.05592
Balance, Per KWH	0.05366

Minimum Bill:

The minimum monthly charge shall be the greater of: \$3.57 plus the demand charge; \$0.60/kVA connected load or \$5.96 for three phase.

Reactive Power Adjustment:

The department, at its option, may measure the reactive power taken. A charge of \$0.01 shall be made for each lagging kilowatt hour per month that exceeds thirty-three (33) percent of the kilowatt hours used in the month. Leading kilowatt hours will not be credited against lagging kilowatt hours. (Reactive adjustment will be zero if the power factor is 95 percent or greater.)

Metering Adjustment:

When the department installs a primary meter that does not compensate for transformer losses, the customer's total bill including fuel adjustment and reactive power adjustment shall be decreased by two (2) percent. No discount is allowed when the department furnishes more than one transformer bank.

Determination of Demand:

Kilowatt demand will be determined by suitable demand instruments or at the department's option, by demand tests, and shall be the highest average kilowatt demand measured in any thirty-minute period during the month. Customers using less than 3,000 KWH per month for twelve consecutive months will not be subject to the demand charge.

Metering Option:

At the department's option, suitable metering equipment may be installed on the primary side of the transformer serving the customer.